

Ontario Drinking-Water Systems Regulation O. Reg. 170-03 (s)11

Stayner 2017 Annual Report

Drinking-Water System Number: 220001138
Drinking-Water System Name: Stayner Drinking Water System
Drinking-Water System Owner: The Corporation of the Township of Clearview
Drinking-Water System Category: Large Municipal Residential
Period being reported: January – December 2017

This Drinking-Water System does not serve more than 10,000 people.

This annual report is available to the public at no charge on the Clearview website at www.clearview.ca

The Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection at the Clearview Municipal Office 217 Gideon Street, Stayner and at the Clearview public works building at 5833 27/28 Side Road, Stayner.

No other Drinking Water Systems receive their drinking water from this system.

This annual report is available free of charge on our web-site, and at the locations listed above. Notice of the report availability is provided on the Clearview web-site and on digital signboards throughout Clearview. Report availability is also advertised in the local newspaper.

Description of the system:

The water source for this system is four groundwater source wells. Disinfection is provided with sodium hypochlorite. ClearHib5 (blended phosphates) is used to sequester iron. Water storage is in two glass-lined steel tanks with a total capacity of 7100 m³. There are approximately 1624 active service connections. There are 201 hydrants throughout the system for fire protection.

Chemicals used for treatment include 12% Sodium Hypochlorite and ClearHib 5 blended phosphates.

Significant expenses incurred to install, repair, or replace equipment:

Wells # 2 & 4 Upgrades: \$620,420
Scott St. Watermain Replacement: \$611,300
Well # 1 Building Upgrades: \$9,900
Reservoir Building Shingle Replacement: \$4,345

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
08/06/2017	Pressure	0	PSI	Repaired damaged temporary watermain. Restored pressure. Collected bacti sample	08/06/2017

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

Type of Sample	Number of Samples	Range of E.coli Or Fecal Results (min #)- (max #) CFU/100 mL	Range of Total Coliform Results (min #)- (max #) CFU/100 mL	Number of HPC Samples	Range of HPC Results (min #)- (max #) CFU/100 mL
Raw – Well # 1	52	0 – 0	0 – 0	0	NA
Raw – Well # 2	44	0 – 0	0 – 4	0	NA
Raw – Well # 3	52	0 – 0	0 – 0	0	NA
Raw – Well # 4	39	0 – 0	0 – 25	0	NA
Treated – Well # 1	52	0 – 0	0 – 0	52	<10 – 30
Treated – Well # 2/4	49	0 – 0	0 – 0	49	<10 – 280
Treated – Well # 3	52	0 – 0	0 – 0	52	<10 – 420
Distribution	156	0 – 0	0 – 0	40	<10->2000

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Parameter	Number of Grab Samples	Range of Results (min #)- (max #)	Unit of Measure
System Chlorine	431	0.26 – 1.51	mg/L
Chlorine			
Well # 1	8760	0.31 – 1.74	mg/L
Well # 2/4	8760	0.30 – 1.84	mg/L
Well # 3	8760	0.30 – 2.25	mg/L
Turbidity			
Raw – Well # 1	12	0.69 – 1.48	NTU
Raw – Well # 2	11	0.73 – 1.48	NTU
Raw – Well # 3	12	0.76 – 1.70	NTU
Raw – Well # 4	9	0.61 – 1.41	NTU

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of lead testing under Schedule 15.1 during this reporting period (applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	0	NA	mg/L	NA
Distribution	0	NA	mg/L	NA

Samples required under Schedule 13

Parameter	Last Date Sampled	Result	Unit of Measure
THM's (annual running average)	10/17/2017	0.0141	mg/L
HAA's (annual running average)	10/17/2017	0.0077	mg/L
Nitrate – Well # 1	10/17/2017	0.4	mg/L
Nitrate – Well # 2/4	10/17/2017	6.7	mg/L
Nitrate – Well # 3	10/17/2017	0.3	mg/L
Nitrite – Well # 1	10/17/2017	0.2	mg/L
Nitrite – Well # 2/4	10/17/2017	0.2	mg/L
Nitrite – Well # 3	10/17/2017	0.2	mg/L
Sodium – Well # 1	10/09/2014	10.0	mg/L
Sodium – Well # 2	10/09/2014	7.4	mg/L
Sodium – Well # 3	10/09/2014	7.4	mg/L
Fluoride – Well # 1	07/18/2017	<0.1	mg/L
Fluoride – Well # 2/4	07/18/2017	<0.1	mg/L
Fluoride – Well # 3	07/18/2017	<0.1	mg/L

The most recent sample results of Inorganic parameters tested during this reporting period.

– Appendix – A

The most recent sample results of Organic parameters sampled during this reporting period.

– Appendix – B

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. N/A

APPENDIX A
INORGANIC PARAMETERS
(SCHEDULE 23)

C.O.C.: DWCV161206A

REPORT No. B16-36439

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

110 West Beaver Creek Rd Unit 14
 Richmond Hill ON L4B 1J9
 Tel: 289-475-5442
 Fax: 289-562-1963

DATE RECEIVED: 06-Dec-16

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 09-Dec-16

P.O. NUMBER: Sch.23

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	ST # 1 Treated	ST # 2 Treated	ST # 3 Treated	
Sample I.D.	B16-36439-1	B16-36439-2	B16-36439-3	
Date Collected	06-Dec-16	06-Dec-16	06-Dec-16	

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Antimony	mg/L	0.0001	EPA 200.8	08-Dec-16/O	< 0.0001	< 0.0001	< 0.0001	
Arsenic	mg/L	0.0001	EPA 200.8	08-Dec-16/O	0.0008	0.0006	0.0008	
Barium	mg/L	0.001	SM 3120	08-Dec-16/O	0.077	0.050	0.068	
Boron	mg/L	0.005	SM 3120	08-Dec-16/O	0.011	0.006	0.010	
Cadmium	mg/L	0.00002	EPA 200.8	08-Dec-16/O	< 0.00002	< 0.00002	< 0.00002	
Chromium	mg/L	0.002	SM 3120	08-Dec-16/O	< 0.002	< 0.002	< 0.002	
Mercury	mg/L	0.00002	SM 3112 B	09-Dec-16/O	< 0.00002	< 0.00002	< 0.00002	
Selenium	mg/L	0.001	EPA 200.8	08-Dec-16/O	< 0.001	< 0.001	< 0.001	
Uranium	mg/L	0.00005	EPA 200.8	08-Dec-16/O	0.00075	0.00093	0.00077	
Free Chlorine	mg/L		n/a	06-Dec-16/R	1.14	0.90	1.26	

1 Free Chlorine results provided by client.



Christine Burke
 Lab Manager

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

APPENDIX B
ORGANIC PARAMETERS
(SCHEDULE 24)

C.O.C.: DW 04083

REPORT No. B15-04083

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 27-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 11-Mar-15


P.O. NUMBER: Schedule 24

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #1 Treated Entering			
Sample I.D.	B15-04083-1			
Date Collected	26-Feb-15			

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Benzene	µg/L	0.5	EPA 8260	04-Mar-15/O	< 0.5		
Carbon Tetrachloride	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		
Dichlorobenzene, 1,2-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		
Dichlorobenzene, 1,4-	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		
Dichloroethane, 1,2-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		
Dichloroethane, 1,1-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		
Dichloromethane (Methylene Chloride)	µg/L	0.3	EPA 8260	04-Mar-15/O	< 0.3		
Monochlorobenzene (Chlorobenzene)	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		
Tetrachloroethylene	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		
Trichloroethylene	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		
Vinyl Chloride	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		
Alachlor	µg/L	0.3	EPA 8270	03-Mar-15/K	< 0.3		
Aldicarb	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Aldrin + Dieldrin	µg/L	0.02	EPA 8080	05-Mar-15/K	< 0.02		
Atrazine + Metabolites	µg/L	0.5	Calc.	03-Mar-15/K	< 0.5		
Azinphos-methyl	µg/L	1	EPA 8270	03-Mar-15/K	< 1		
Bendiocarb	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Benzo(a)pyrene	µg/L	0.005	EPA 8270	03-Mar-15/K	< 0.005		
Bromoxynil	µg/L	0.3	EPA 8270	03-Mar-15/K	< 0.3		
Carbaryl	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Carbofuran	µg/L	1	EPA 8270	03-Mar-15/K	< 1		
Chlordane (Total)	µg/L	0.04	EPA 8080	05-Mar-15/K	< 0.04		
Chlorpyrifos	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5		
Cyanazine	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5		
DDT + Metabolites	µg/L	0.01	EPA 8080	05-Mar-15/K	< 0.01		



Gord Murphy
 Lab Supervisor

M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill

C.O.C.: DW 04083

REPORT No. B15-04083

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 27-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 11-Mar-15


P.O. NUMBER: Schedule 24

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #1 Treated Entering			
Sample I.D.	B15-04083-1			
Date Collected	26-Feb-15			

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Diazinon	µg/L	1	EPA 8270	03-Mar-15/K	< 1		
Dicamba	µg/L	5	EPA 8270	03-Mar-15/K	< 5		
Dichlorophenol, 2,4-	µg/L	0.1	EPA 8270	03-Mar-15/K	< 0.1		
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	µg/L	5	EPA 8270	03-Mar-15/K	< 5		
Diclofop-methyl	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5		
Dimethoate	µg/L	1	EPA 8270	03-Mar-15/K	< 1		
Dinoseb	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5		
Diquat	µg/L	5	EPA 549.1	06-Mar-15/K	< 5		
Diuron	µg/L	5	EPA 8270	03-Mar-15/K	< 5		
Glyphosate	µg/L	25	EPA 547	06-Mar-15/K	< 25		
Heptachlor + Heptachlor Epoxide	µg/L	0.1	EPA 8080	05-Mar-15/K	< 0.1		
Lindane (Hexachlorocyclohexane, Gamma)	µg/L	0.1	EPA 8080	05-Mar-15/K	< 0.1		
Malathion	µg/L	5	EPA 8270	03-Mar-15/K	< 5		
Methoxychlor	µg/L	0.1	EPA 8080	05-Mar-15/K	< 0.1		
Metolachlor	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Metribuzin	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Paraquat	µg/L	1	EPA 549.1	06-Mar-15/K	< 1		
Parathion	µg/L	3	EPA 8270	03-Mar-15/K	< 3		
Pentachlorophenol	µg/L	0.1	EPA 8270	03-Mar-15/K	< 0.1		
Phorate	µg/L	0.3	EPA 8270	03-Mar-15/K	< 0.3		
Picloram	µg/L	5	EPA 8270	03-Mar-15/K	< 5		
Poly-Chlorinated Biphenyls (PCB's)	µg/L	0.05	EPA 8080	05-Mar-15/K	< 0.05		



Gord Murphy
 Lab Supervisor

M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill

C.O.C.: DW 04083

REPORT No. B15-04083

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 27-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 11-Mar-15


P.O. NUMBER: Schedule 24

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #1 Treated Entering			
Sample I.D.	B15-04083-1			
Date Collected	26-Feb-15			

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Prometryne	µg/L	0.1	EPA 8270	03-Mar-15/K	< 0.1			
Simazine	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5			
Temephos	µg/L	10	EPA 8270	03-Mar-15/K	< 10			
Terbufos	µg/L	0.3	EPA 8270	03-Mar-15/K	< 0.3			
Tetrachlorophenol, 2,3,4,6-	µg/L	0.1	EPA 8270	03-Mar-15/K	< 0.1			
Triallate	µg/L	10	EPA 8270	03-Mar-15/K	< 10			
Trichlorophenol 2,4,6-	µg/L	0.1	EPA 8270	03-Mar-15/K	< 0.1			
Trichlorophenoxy acetic acid, 2,4,5-	µg/L	10	EPA 8270	03-Mar-15/K	< 10			
Trifluralin	µg/L	0.5	EPA 8270	03-Mar-15/K	< 0.5			



Gord Murphy
 Lab Supervisor

M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

C.O.C.: DW 03572

REPORT No. B15-03572

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 20-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 06-Mar-15

P.O. NUMBER:


SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #2 Treated Entering	Well #3 Treated Entering	Well #3 Treated Entering - Resample	
Sample I.D.	B15-03572-1	B15-03572-2	B15-03572-3	
Date Collected	19-Feb-15	19-Feb-15	03-Mar-15	

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Benzene	µg/L	0.5	EPA 8260	04-Mar-15/O	< 0.5		< 0.5	
Carbon Tetrachloride	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		< 0.2	
Dichlorobenzene, 1,2-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		< 0.1	
Dichlorobenzene, 1,4-	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		< 0.2	
Dichloroethane, 1,2-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		< 0.1	
Dichloroethane, 1,1-	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		< 0.1	
Dichloromethane (Methylene Chloride)	µg/L	0.3	EPA 8260	04-Mar-15/O	< 0.3		< 0.3	
Monochlorobenzene (Chlorobenzene)	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		< 0.2	
Tetrachloroethylene	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		< 0.2	
Trichloroethylene	µg/L	0.1	EPA 8260	04-Mar-15/O	< 0.1		< 0.1	
Vinyl Chloride	µg/L	0.2	EPA 8260	04-Mar-15/O	< 0.2		< 0.2	
Alachlor	µg/L	0.3	EPA 8270	25-Feb-15/K	< 0.3	< 0.3		
Aldicarb	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Aldrin + Dieldrin	µg/L	0.02	EPA 8080	26-Feb-15/K	< 0.02	< 0.02		
Atrazine + Metabolites	µg/L	0.5	Calc.	25-Feb-15/K	< 0.5	< 0.5		
Azinphos-methyl	µg/L	1	EPA 8270	25-Feb-15/K	< 1	< 1		
Bendiocarb	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Benzo(a)pyrene	µg/L	0.005	EPA 8270	25-Feb-15/K	< 0.005	< 0.005		
Bromoxynil	µg/L	0.3	EPA 8270	25-Feb-15/K	< 0.3	< 0.3		
Carbaryl	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Carbofuran	µg/L	1	EPA 8270	25-Feb-15/K	< 1	< 1		
Chlordane (Total)	µg/L	0.04	EPA 8080	26-Feb-15/K	< 0.04	< 0.04		
Chlorpyrifos	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		
Cyanazine	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		

Note: #3 sample was a resample because of Run Failure.



M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston, W-Windsor, O-Ottawa, R-Richmond Hill

Gord Murphy
 Lab Supervisor

C.O.C.: DW 03572

REPORT No. B15-03572

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 20-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 06-Mar-15

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #2 Treated Entering	Well #3 Treated Entering	Well #3 Treated Entering - Resample	
Sample I.D.	B15-03572-1	B15-03572-2	B15-03572-3	
Date Collected	19-Feb-15	19-Feb-15	03-Mar-15	

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
DDT + Metabolites	µg/L	0.01	EPA 8080	26-Feb-15/K	< 0.01	< 0.01		
Diazinon	µg/L	1	EPA 8270	25-Feb-15/K	< 1	< 1		
Dicamba	µg/L	5	EPA 8270	25-Feb-15/K	< 5	< 5		
Dichlorophenol, 2,4-	µg/L	0.1	EPA 8270	25-Feb-15/K	< 0.1	< 0.1		
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	µg/L	5	EPA 8270	25-Feb-15/K	< 5	< 5		
Diclofop-methyl	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		
Dimethoate	µg/L	1	EPA 8270	25-Feb-15/K	< 1	< 1		
Dinoseb	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		
Diquat	µg/L	5	EPA 549.1	27-Feb-15/K	< 5	< 5		
Diuron	µg/L	5	EPA 8270	25-Feb-15/K	< 5	< 5		
Glyphosate	µg/L	25	EPA 547	27-Feb-15/K	< 25	< 25		
Heptachlor + Heptachlor Epoxide	µg/L	0.1	EPA 8080	26-Feb-15/K	< 0.1	< 0.1		
Lindane (Hexachlorocyclohexane, Gamma)	µg/L	0.1	EPA 8080	26-Feb-15/K	< 0.1	< 0.1		
Malathion	µg/L	5	EPA 8270	25-Feb-15/K	< 5	< 5		
Methoxychlor	µg/L	0.1	EPA 8080	26-Feb-15/K	< 0.1	< 0.1		
Metolachlor	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Metribuzin	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Paraquat	µg/L	1	EPA 549.1	27-Feb-15/K	< 1	< 1		
Parathion	µg/L	3	EPA 8270	25-Feb-15/K	< 3	< 3		
Pentachlorophenol	µg/L	0.1	EPA 8270	25-Feb-15/K	< 0.1	< 0.1		
Phorate	µg/L	0.3	EPA 8270	25-Feb-15/K	< 0.3	< 0.3		
Picloram	µg/L	5	EPA 8270	25-Feb-15/K	< 5	< 5		

Note: #3 sample was a resample because of Run Failure.



Gord Murphy
 Lab Supervisor

M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

C.O.C.: DW 03572

REPORT No. B15-03572

Report To:

Clearview, Township of
 217 Gideon Street, Box 200
 Stayner Ontario L0M 1S0 Canada

Attention: Todd Patton

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa Ontario K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 20-Feb-15

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 06-Mar-15

P.O. NUMBER:


SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Client I.D.	Well #2 Treated Entering	Well #3 Treated Entering	Well #3 Treated Entering - Resample	
Sample I.D.	B15-03572-1	B15-03572-2	B15-03572-3	
Date Collected	19-Feb-15	19-Feb-15	03-Mar-15	

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Poly-Chlorinated Biphenyls (PCB's)	µg/L	0.05	EPA 8080	26-Feb-15/K	< 0.05	< 0.05		
Prometryne	µg/L	0.1	EPA 8270	25-Feb-15/K	< 0.1	< 0.1		
Simazine	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		
Temephos	µg/L	10	EPA 8270	25-Feb-15/K	< 10	< 10		
Terbufos	µg/L	0.3	EPA 8270	25-Feb-15/K	< 0.3	< 0.3		
Tetrachlorophenol, 2,3,4,6-	µg/L	0.1	EPA 8270	25-Feb-15/K	< 0.1	< 0.1		
Triallate	µg/L	10	EPA 8270	25-Feb-15/K	< 10	< 10		
Trichlorophenol 2,4,6-	µg/L	0.1	EPA 8270	25-Feb-15/K	< 0.1	< 0.1		
Trichlorophenoxy acetic acid, 2,4,5-	µg/L	10	EPA 8270	25-Feb-15/K	< 10	< 10		
Trifluralin	µg/L	0.5	EPA 8270	25-Feb-15/K	< 0.5	< 0.5		

Note: #3 sample was a resample because of Run Failure.



M.D.L. = Method Detection Limit
 Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Gord Murphy
 Lab Supervisor